



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 1 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Attached is the analytical report for the sample(s) received for your project. Below is a list of the individual sample descriptions with the corresponding laboratory number(s). Also, enclosed is a copy of the Chain of Custody document (if received with your sample(s)). Please note any unused portion of the sample(s) may be responsibly discarded after 30 days from the above report date, unless you have requested otherwise.

Thank you for the opportunity to serve your analytical needs. If you have any questions or concerns regarding this report please contact our client service department.

Sample Identification

<u>Lab Sample #</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>By</u>	<u>Date Submitted</u>	<u>By</u>
B8D0668-01	Kinder Playground D.F.	Water	04/05/18 10:50	Kevin Feddock	04/05/18 12:20	Kevin Feddock
B8D0668-02	"C" Blg D.F.	Water	04/05/18 10:53	Kevin Feddock	04/05/18 12:20	Kevin Feddock
B8D0668-03	"F" Blg D.F.	Water	04/05/18 10:55	Kevin Feddock	04/05/18 12:20	Kevin Feddock
B8D0668-04	"D" Blg D.F.	Water	04/05/18 10:57	Kevin Feddock	04/05/18 12:20	Kevin Feddock
B8D0668-05	Portable Blg D.F.	Water	04/05/18 10:59	Kevin Feddock	04/05/18 12:20	Kevin Feddock



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 2 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Laboratory Reference Number

B8D0668-01

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
Kinder Playground D.F.	Water	04/05/18 10:50	04/05/18 12:20

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Metals and Metalloids Lead	ND	5.0	ug/L	EPA 200.8	04/12/18 18:27	MEL	



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 3 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Laboratory Reference Number

B8D0668-02

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
"C" Blg D.F.	Water	04/05/18 10:53	04/05/18 12:20

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Metals and Metalloids							
Lead	ND	5.0	ug/L	EPA 200.8	04/12/18 18:30	MEL	



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 4 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Laboratory Reference Number

B8D0668-03

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
"F" Blg D.F.	Water	04/05/18 10:55	04/05/18 12:20

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Metals and Metalloids							
Lead	ND	5.0	ug/L	EPA 200.8	04/12/18 18:32	MEL	



BABCOCK Laboratories, Inc.

The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 5 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Laboratory Reference Number

B8D0668-04

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
"D" Blg D.F.	Water	04/05/18 10:57	04/05/18 12:20

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Metals and Metalloids							
Lead	ND	5.0	ug/L	EPA 200.8	04/12/18 19:01	MEL	

mailing

P.O Box 432
Riverside, CA 92502-0432

location

6100 Quail Valley Court
Riverside, CA 92507-0704

P 951 653 3351
F 951 653 1662
www.babcocklabs.com

CA ELAP No. 2698
EPA No. CA00102
NELAP No. OR4035
LACSD No. 10119



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 6 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Laboratory Reference Number

B8D0668-05

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
Portable Blg D.F.	Water	04/05/18 10:59	04/05/18 12:20

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Metals and Metalloids							
Lead	ND	5.0	ug/L	EPA 200.8	04/12/18 19:04	MEL	



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Kevin Feddock
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 7 of 7
Project Name: Menifee USD-Misc
Project Number: Freedom Crest

Report Date: 17-Apr-2018

Work Order Number: B8D0668

Received on Ice (Y/N): Yes Temp: 22 °C

Notes and Definitions

ND: Analyte NOT DETECTED at or above the Method Detection Limit (**if MDL is reported**), otherwise at or above the Reportable Detection Limit (RDL)
NR: Not Reported
RDL: Reportable Detection Limit
MDL: Method Detection Limit
* / " : NELAP does not offer accreditation for this analyte/method/matrix combination

Approval

Enclosed are the analytical results for the submitted sample(s). Babcock Laboratories certify the data presented as part of this report meet the minimum quality standards in the referenced analytical methods. Any exceptions have been noted.

Janie M. Bernal For Amanda C. Porter

cc:

e-Short_No Alias.rpt

This report applies only to the sample(s) analyzed. As a mutual protection to clients, the public, and Babcock Laboratories, Inc., this report is submitted and accepted for the exclusive use of the Client to whom it is addressed. Interpretation and use of the information contained within this report are the sole responsibility of the Client. Babcock Laboratories, Inc. is not responsible for any misinformation or consequences that may result from misinterpretation or improper use of this report. This report is not to be modified or abbreviated in any way. Additionally, this report is not to be used, in whole or in part, in any advertising or publicity matter without written authorization from Babcock Laboratories, Inc. The liability of Babcock Laboratories, Inc. is limited to the actual cost of the requested analyses, unless otherwise agreed upon in writing. There is no other warranty expressed or implied.

mailing

P.O Box 432
Riverside, CA 92502-0432

location

6100 Quail Valley Court
Riverside, CA 92507-0704

P 951 653 3351
F 951 653 1662
www.babcocklabs.com

CA ELAP No. 2698
EPA No. CA00102
NELAP No. OR4035
LACSD No. 10119



BABCOCK Laboratories, Inc.
The Standard of Excellence for Over 100 Years

Client Name: Menifee USD
Contact: Bruce Shaw
Address: 29775 Haun Road
Menifee, CA 92586

Analytical Report: Page 3 of 9
Project Name: Menifee USD-bacti DW
Project Number: [none]

Report Date: 03-Apr-2018

Work Order Number: B8C2403

Received on Ice (Y/N): Yes Temp: 5 °C

Laboratory Reference Number

B8C2403-02

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
Freedom Crest Elementary	Water	03/26/18 09:01	03/26/18 9:43

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
Heterotrophic Plate Count - SM 9215 B							
Heterotrophic Plate Count	>5700	1.0	CFU/mL	SM 9215B	03/28/18 14:15	CAK	
MMOMUG - Presence/Absence - SM 9223 B							
Total Coliform	Absent	1.1	----	SM 9223B	03/27/18 10:10	SAR	
E. coli	Absent	1.1	----	SM 9223B	03/27/18 10:10	SAR	